

## DATA SHEET 01 TO EC-TYPE-EXAMINATION CERTIFICATE PTB 09 ATEX 3004

**Manufacturer:** VEM motors GmbH

Carl-Friedrich-Gauß-Str. 1, 38855 Wernigerode, Germany

for three-phase motor of the type K10R 112 M2 Exell...

### Ratings

This certificate is valid for the following designs providing the motors of this type differ only negligibly from the sample tested as regards the electrical and thermal stresses:

Power:		5.5		kW
Voltage:	220	380	690	V
Current:	18.9	10.9	6	A
Power factor:		0.86		
Frequency:		50		Hz
Speed: (motor)		2925		min <sup>-1</sup>
Duty Type:		S1		
I <sub>A</sub> /I <sub>N</sub> ratio:		8.5		
Thermal class:		F		

In addition to the above-mentioned voltages, intermediate values are also permissible. The associated currents are to be converted in the inverse ratio to the voltages. The mains voltage may vary by up to  $\pm 5\%$  and the mains frequency by up to  $\pm 2\%$  from the rated values, in keeping with range A according to IEC 60034-1.

### Temperature monitoring

For the selection of a current dependent time-lag protective device, the times  $t_E$  were determined as follows:


Temperature class:	T1	T2	T3	
Time $t_E$ :	16	16	6	s

### Assessment and test report PTB Ex 98-30004

Zertifizierungssektor Explosionsschutz

By order

Braunschweig, April 27, 2009



Dr.-Ing. F. Lienesch  
Regierungsdirektor

