

# IBExU Institut für Sicherheitstechnik GmbH

An-Institut der TU Bergakademie Freiberg

## Continuation Sheet 36

### to the EC-TYPE EXAMINATION CERTIFICATE IBExU99ATEX1143 (Translation)

Three-phase Asynchronous Motor with Squirrel-Cage Rotor type IE2-K11R 200 L2

#### Rated values and technical data

On the basis of the test report IB-11-3-077 of 22 June 2011 the following specifications result:

The details are valid under the prerequisite that the Three-phase Motors of this type differ only insignificantly from the tested sample concerning the electrical and thermal design.

Nominal power:		23			kW
Nominal voltage:	220	480	690		V
Nominal current:	72	33	23		A
Power factor:		0.91			
Nominal frequency:		60			Hz
Nominal speed:		3552			min <sup>-1</sup>
Operation mode:		S1			
Ratio $I_A/I_N$ :		8.2			
Thermal class:		F			
Cooling medium temperature:		40			°C

Besides the voltages mentioned above also intermediary values are permissible.  
The related currents have to be converted in the reciprocal relation of the voltages.  
In comparison with the rated values the mains voltage may fluctuate up to  $\pm 5\%$  and the mains frequency up to  $\pm 2\%$  appropriate to range A according to IEC 60034-1.

#### Temperature control

For the current-dependent delayed protective device the following  $t_E$ -times are valid:

Temperature class:	T1	T2	T3
Time $t_E$ :	19 s	19 s	8 s

This Continuation Sheet is only valid in combination with the EC-Type Examination Certificate IBExU99ATEX1143.

**IBExU** Institut für Sicherheitstechnik GmbH  
Fuchsmühlenweg 7 - 09599 Freiberg, GERMANY  
☎ +49 (0) 3731 3805-0 - 📠 +49 (0) 3731 23650

Authorised for certifications

Freiberg, 22 June 2011

By order

(Dipl.-Ing. Willamowski)



Certificates without signature and seal are not valid. Certificates may only be duplicated completely and unchanged. In case of dispute, the German text shall prevail.