

## DATA SHEET 08 TO EC-TYPE-EXAMINATION CERTIFICATE PTB 08 ATEX 3040

**Manufacturer:** VEM motors GmbH  
Carl-Friedrich-Gauß-Str. 1, 38855 Wernigerode, Germany

for the three-phase motor type K11R 200 LX2 Exell ...

### Ratings

This certificate is valid for the following designs providing the motors of this type differ only negligibly from the sample tested as regards the electrical and thermal stresses:

Power:		31		kW
Voltage:	220	400	690	V
Current:	98	54	31.5	A
Power factor:		0.90		
Frequency:		50		Hz
Speed: (motor)		2925		min <sup>-1</sup>
Duty Type:		S1		
I <sub>A</sub> /I <sub>N</sub> ratio:		5.3		
Thermal class:		F		

In addition to the above-mentioned voltages, intermediate values are also permissible. The associated currents are to be converted in the inverse ratio to the voltages. The mains voltage may vary by up to  $\pm 5\%$  and the mains frequency by up to  $\pm 2\%$  from the rated values, in keeping with range A according to IEC 60034-1.

### Temperature monitoring

For the selection of a current dependent time-lag protective device, the times  $t_E$  were determined as follows:

Temperature class:	T1	T2	
Time $t_E$ :	16	16	s

### Assessment and test report PTB Ex 98-30012

Zertifizierungssektor Explosionsschutz  
By order

Braunschweig, March 09, 2009

  
Dr.-Ing. F. Lienesch  
Regierungsdirektor

