

# IBExU Institut für Sicherheitstechnik GmbH

An-Institut der TU Bergakademie Freiberg

## Continuation Sheet 36

### to the EC-TYPE EXAMINATION CERTIFICATE IBExU99ATEX1131 (Translation)

Three-phase Asynchronous Motor with Squirrel-Cage Rotor type IE3-K11R 250 M4

#### Rated values and technical data

On the basis of the test report IB-12-3-174 of 13 September 2012 the following specifications result:

The details are valid under the prerequisite that the Three-phase Motors of this type differ only insignificantly from the tested sample concerning the electrical and thermal design.

Nominal power:		50		kW
Nominal voltage:	220	400	690	V
Nominal current:	164	90	52	A
Power factor:		0.85		
Nominal frequency:		50		Hz
Nominal speed:		1484		min <sup>-1</sup>
Operation mode:		S1		
Ratio I <sub>A</sub> /I <sub>N</sub> :		7.0		
Thermal class:		F		
Cooling medium temperature:		45		°C

Besides the voltages mentioned above also intermediary values are permissible.  
The related currents have to be converted in the reciprocal relation of the voltages.  
In comparison with the rated values the mains voltage may fluctuate up to ± 5 % and the mains frequency up to ± 2 % appropriate to range A according to IEC 60034-1.

#### Temperature control

For the current-dependent delayed protective device the following t<sub>E</sub>-times are valid:

Temperature class:	T1	T2	T3
Time t <sub>E</sub> :	25 s	25 s	7 s

This Continuation Sheet is only valid in combination with the EC-Type Examination Certificate IBExU99ATEX1131.

IBExU Institut für Sicherheitstechnik GmbH  
Fuchsmühlenweg 7 - 09599 Freiberg, GERMANY  
☎ +49 (0) 3731 3805-0 - ☎ +49 (0) 3731 23650

Authorised for certifications  
-Explosion protection-

By order



(Dr. Wagner)



Seal  
(ID no. 0637)

Freiberg, 13 September 2012

Certificates without signature and seal are not valid.  
Certificates may only be duplicated completely and unchanged. In case of dispute, the German text shall prevail.