

Continuation Sheet 13

to the EC-TYPE EXAMINATION CERTIFICATE IBExU01ATEX1009
(Translation)

Three-phase Asynchronous Motor with Squirrel-Cage Rotor type K12R 355 M4

Rated values and technical data

On the basis of the test report IB-12-3-184 of 20 August 2012 the following specifications result:

The details are valid under the prerequisite that the Three-phase Motors of this type differ only insignificantly from the tested sample concerning the electrical and thermal design.

Nominal power:		215		kW
Nominal voltage:	220	440	690	V
Nominal current:	710	355	225	A
Power factor:		0.84		
Nominal frequency:		60		Hz
Nominal speed:		1793		min ⁻¹
Operation mode:		S1		
Ratio I_A/I_N :		7.5		
Thermal class:		F		
Cooling medium temperature:		40		°C

Besides the voltages mentioned above also intermediary values are permissible.
The related currents have to be converted in the reciprocal relation of the voltages.
In comparison with the rated values the mains voltage may fluctuate up to $\pm 5\%$ and the mains frequency up to $\pm 2\%$ appropriate to range A according to IEC 60034-1.

Temperature control

For the current-dependent delayed protective device the following t_E -times are valid:

Temperature class:	T1	T2	T3
Time t_E :	22 s	22 s	8 s

This Continuation Sheet is only valid in combination with the EC-Type Examination Certificate IBExU01ATEX1009.

IBExU Institut für Sicherheitstechnik GmbH
Fuchsmühlenweg 7 - 09599 Freiberg, GERMANY
☎ +49 (0) 3731 3805-0 - ☎ +49 (0) 3731 23650

Authorised for certifications
-Explosion protection-

By order



(Dr. Wagner)



Seal
(ID no. 0637)

Freiberg, 20 August 2012

Certificates without signature and seal are not valid.
Certificates may only be duplicated completely and unchanged. In case of dispute, the German text shall prevail.