

Continuation Sheet 36

to the EC-TYPE EXAMINATION CERTIFICATE IBExU02ATEX1114 (Translation)

Three-phase Asynchronous Motor with Squirrel-Cage Rotor type IE2-KPR 100L2

Rated values and technical data

On the basis of the test report IB-10-3-377 of 03 January 2011 the following specifications result:

The details are valid under the prerequisite that the Three-phase Motors of this type differ only insignificantly from the tested sample concerning the electrical and thermal design.

Nominal power:		2.5		kW
Nominal voltage:	126 ... 140	380 ... 420	660 ... 725	V
Nominal current:	14.7	4.9	2.85	A
Power factor:		0.90 ... 0.87		
Nominal frequency:		50		Hz
Nominal speed:		2890 ... 2920		min ⁻¹
Operation mode:		S1		
Ratio I _A /I _N :		6.8		
Thermal class:		F		
Cooling medium temperature:		50		°C

Besides the voltages mentioned above also intermediary values are permissible.
The related currents have to be converted in the reciprocal relation of the voltages.
In comparison with the rated values the mains voltage may fluctuate up to ± 5 % and the mains frequency up to ± 2 % appropriate to range A according to IEC 60034-1.

Temperature control

For the current-dependent delayed protective device the following t_E-times are valid:

Temperature class:	T1	T2	T3
Time t _E :	34 s	34 s	25 s

This Continuation Sheet is only valid in combination with the EC-Type Examination Certificate IBExU02ATEX1114.

IBExU Institut für Sicherheitstechnik GmbH
Fuchsmühlenweg 7 - 09599 Freiberg, GERMANY
☎ +49 (0) 3731 3805-0 - 📠 +49 (0) 3731 23650

Authorised for certifications
-Explosion protection-

By order



(Dr. Wagner)



- Seal -
(ID no. 0637)

Freiberg, 03 January 2011

Certificates without signature and seal are not valid.
Certificates may only be duplicated completely and unchanged. In case of dispute, the German text shall prevail.