IBExU Institut für Sicherheitstechnik GmbH

An-Institut der TU Bergakademie Freiberg

Addition Sheet 11

to the EC-TYPE EXAMINATION CERTIFICATE IBExU02ATEX1019 (Translation)

Three-phase Asynchronous Motor with Squirrel-Cage Rotor type K21Q 225 S8-2 (K20Q 200 L8-2)

The already certified motor series type K2.Q ... Ex II 2D is extended with the motor type K21Q 225 S8-2 (K20Q 200 L8-2). The motor is intended for use at a maximum surface temperature of $T = 125 \,^{\circ}\text{C}$.

Rated values and technical data

		8-pole	2-pole
Power:	kW	6.7	26.5
Voltage:	V	400	400
Current:	Α	21.5	47.5
Frequency:	Hz	50	50
Speed:	min ⁻¹	740	2965
Power factor:		0.55	0.91
Efficiency:	%	83.1	88.6
Operation mode:		S1	S1
Cooling medium temperature:	°C	40	40

Besides the voltage 400 V also other voltages in the range from 220 V up to 690 V are permissible. The related currents are converted in the reciprocal relation of the voltages.

Compared with the rated values the mains voltage may fluctuate up to \pm 5 % and the mains frequency up to \pm 2 % appropriate to range A according to IEC 60034-1.

The proof of explosion protection of the motor mentioned above is recorded in the test report IB-07-3-108 of 18 May 2007. The marking is:

The safety instructions contained in the EC-Type Examination Certificate IBExU02ATEX1019 have to be noticed.

This Addition Sheet is only valid in combination with the EC-Type Examination Certificate IBExU02ATEX1019.

IBExU Institut für Sicherheitstechnik GmbH

Fuchsmühlenweg 7 - 09599 Freiberg, GERMANY

★ +49 (0) 3731 3805-0 - ♣ +49 (0) 3731 23650

Authorised for certifications -Explosion protection-

By order

(Dr. Lösch)

IDEXU Institut für Sicherheitstechnik GmbH

- Seal -(ID no. 0637) Freiberg, 18 May 2007

Certificates without signature and seal are not valid. Certificates may only be duplicated completely and unchanged. In case of dispute, the German text shall prevail.